

## Air Compressors

A Reciprocating Compressor is normally a heavy-duty, continuous service compressor. Cylinder construction usually incorporates a water jacketed cylinder and water jacketed heads to remove some of the heat of compression and also to improve the lubrication and reduce carbonization of valve parts. Water jacketing around valve and packing is essential, since these are points of localized heating. As time goes on, you will have lime, water scale and rust accumulation inside the water jackets, which in time, will overheat the air compressor. This will also occur in the intercooler and aftercooler. With **Dynamic Descaler** you can clean these vital parts, without disassembling the cylinders, aftercooler, and the intercooler. Just simply remove the water in/out connection from each part and circulate **Dynamic Descaler** for the recommended amount of time. After the circulation, flush with water and connect the water in/out connections back to the proper location. If your compressor is running off a closed loop water system or a cooling tower, you may want to pour the **Dynamic Descaler** into one of these systems. This will eliminate the downtime in your plant operation versus disconnecting your in/out connections from each vital part. Before you proceed with these operations contact the nearest distributor in your area, so they may be of assistance to you.

Horse Power	Low Pressure Cylinder	High Pressure Cylinder	Intercooler	Aftercooler	Total
30	6-2	6-2	3-1	2-1	17-2
50	10-2	8-2	7-1	5-1	30-2
100	14-3	10-3	11-1	7-1	42-3
125	18-3	13-3	15-1	9-2	55-3
150	26-3	16-3	19-1	11-1	72-3
200	30-3	20-3	27-2	17-1	94-4
250	34-4	22-4	35-2	21-2	112-4
300	38-4	24-4	41-2	25-2	128-4
500	42-4	28-4	44-2	29-2	143-4
700	50-4	35-4	48-2	33-2	166-4
1000	62-5	47-5	60-3	45-3	214-5

\* Gallons-Hours of circulation.

Example: If a compressor is 50 H.P. and the low pressure cylinder is to be cleaned. It would take ten (10) gallons of **Dynamic Descaler** and approximately two (2) hours to clean it. To clean the high pressure cylinder you would need an additional eight (8) gallons of **Dynamic Descaler**. It would then take eighteen gallons of **Dynamic Descaler** and approximately two (2) hours to clean the high pressure and low pressure cylinders. For proper quantity and circulating times to run **Dynamic Descaler** through the cooling tower or closed loop water system to clean the compressor, (without shutting down plant operations), please contact the nearest **Dynamic Descaler** distributor in your area.

» **Precision Dynamics, Inc.**  
 P.O. Box 1595  
 Burlson, Texas, USA, 76097  
**USA Toll Free Telephone:** 800 388-5818  
**International Telephone:** 817 447-9898  
**USA Fax:** 817 447-1126  
**web site:** [www.dynamic-descaler.com](http://www.dynamic-descaler.com)  
**e-mail:** [david@dynamicdescaler.com](mailto:david@dynamicdescaler.com)

» **Tech Sales Co.**  
 10520 Yonge Street, Unit 35B-220  
 Richmond Hill, Ontario, Canada, L4C 3C7  
**Canada Toll Free Telephone:** 1 877 797-2777  
**Canada Toll Free Fax:** 1 877 797-2660  
**International Telephone:** 1 416 410-1313  
**International Fax:** 1 416 410-1806  
**web site:** [www.dynamic-descaler.com](http://www.dynamic-descaler.com)  
**e-mail:** [lesr@tech-sales.com](mailto:lesr@tech-sales.com)